



LEA Associates South Asia Pvt. Ltd.

2nd floor, Sai complex, Ahilya Nagar - Daund Road, (NH.160)
Near of Kinetic Company, Kedgaon, Hanuman Nagar,
Dist. Ahilya Nagar, Maharashtra - 414006,
Email ID: lasa.ae9@gmail.com, www.lea.ca
Corporate Identification Number: U74899DL1993PTC055750

Ref. No: LASA/A.Nagar/AE-9/MH-PWD-73959/2025/390

Date:16.09.2025

To,

The Authorized Signatory

M/s. GHV (India) Pvt. Ltd. In JV with S. B. Deshmukh,
Forcon Infra Pvt. Ltd.,
Deopur, Dhule, Maharashtra-424002.
Email: info@sbdeshmukh.com, pawan@sbdeshmukh.com

Sub:- EPC-59 Improvement of Nashik-Nifad-Yeola-Vaijapur-Aurangabad Road MSH-2 Km 179/00 to 235/00 Tal-Yeola, Dist- Nashik:- **-Provisional Source approval for Admixture & Curing Compound -Reg.**

Ref:- Your Lr. No. GHV/BILLP/EPC 59/2024-25/086 on dated 14.07.2025.

Dear Sir,

With reference to your above-cited letter, the undersigned office has reviewed the submitted documents and found them satisfactory as per IRC-SP 112-2017 and relevant specifications. Accordingly, the following admixture and curing compound suppliers are provisionally approved.

- | | |
|--------------------------------------|---|
| 1) M/s CHEMCORE | - Core Flow -PQC Admixture
Fair Cure RA — PQC Curing Compound
Fair Cure WX — DLC Curing Compound |
| 2) M/s APPLE CHEMIE- | Viscoflux -2203 — PQC Admixture
AC Cure RM — PQC Curing Compound
AC-Cure-S — DLC Curing Compound |
| 3) M/s REDWOP
Chemicals Pvt. Ltd. | - Redbrwan 600 — PQC Admixture
Redicure SB90 — PQC Curing Compound
Redicue-WB - DLC Curing Compound |

Strict adherence to the relevant specifications must be ensured during laboratory and on-site testing to maintain compliance with the Contract Agreement and applicable standards. Regular testing shall be conducted in accordance with IS: 9103 and MoRT&H Clauses 1012.3.1 and 1012.3.2. The Contractor must ensure the following.

1. No modifications shall be made to the manufacturing process or raw materials without prior approval, ensuring full compliance with specified requirements.
2. Material Test Certificates (MTC) must be submitted for verification.

3. Random third-party tests must be conducted, with test results submitted for review and record-keeping.
4. Each supply lot must conform to IS: 1448, IS: 9103, ASTM C-309, and BS: 7542.
5. All materials must comply with the standards and specifications outlined in MoRT&H Clause 1012.03.
6. The curing compound must be applied using a spray method only; manual application is not permitted.

Please note that the source of M/s STP Limited for Shaliculture-AL-WB for PQC & Shaliculture-PA-M-5 for DLC has not been considered as the credentials of the source have not been submitted.

This for your information and for the necessary action accordingly.

**for LEA Associates South Asia Pvt. Ltd.,
in association with EKAM Venture.**


16/09/2025

N. Saravanan.

Team Leader, AE-9.

Ahilyanagar.

Cc:

1. Executive Engineer, PWD. Nashik.
2. Sub-divisional Engineer, Nashik.
3. Resident Engineer, (EPC- 58, 59 & 62)