



Ref: YECL-KC/AE-6/EPC-43/2025/77

E-mail: - ae6.yongmajvkrushnaji@gmail.com

Date: 21/07/2025

**To,**  
**The Project Manager,**  
EPC-43 - Infratech Construction Company,  
Plot No. 21 Great Nag Road, Nagpur - 440009

**Sub:** Improvement to Shirpur Aade Thalner Manjroad Ghodasgaon Holnathe Babhalaji Road MDR-12, from Km. 2/900 to 36/700 (Total Length 32.797 Km.) in Taluka Shirpur, District-Dhule. - **Review / Source Approval of Admixture & Curing Compound-Reg.**

**Ref:**

1. EPC Contractor letter no. ADB/EPC-43/ICC/07/2025/19, Dt. 17-07-2025

Dear Sir,

With reference to your letter cited above, the submitted credentials/ profile of the Source: **REDWOP Chemicals Pvt.Ltd** for supply of chemical Admixture & Curing compound from the vendor have been reviewed & found to be in order, as mentioned below: -

**M/s REDWOP Chemicals Pvt. Ltd,**

Hence, **Source approval** is hereby accorded for the aforesaid source for supply of chemical Admixture-PCE based, Curing Compound-Alumina Resin based in PQC and as well as in concrete/ RCC Structure construction works, under the **following conditions:** -

1. This source approval is subject to the continued compliance and satisfactory performance of admixture & curing compound as per the specifications/standard of **IS:9103** in the project road construction works.
2. **MTC** (manufacturers test certificate) shall be obtained and provided in the field QC laboratory for every batch/ consignment of materials when delivered at site.
3. Third Party laboratory tests to be carried out for all required tests as per codal provision for individual batch/ lot of Admixture & Curing compound when delivered on site.
4. The source approval shall stand cancelled/ withdrawn automatically without any prior notice if the materials found to be unsuitable & fail to comply with the required specifications/standard or the above stated conditions.
5. It may be noted that, this source approval shall not relieve or relax the EPC contractor from their duty, obligations and liabilities as stipulated in the contract agreement.

This is submitted for your information and further necessary action please.

Yours Sincerely,

S. Waris,  
Team Leader,  
Yongma Engineering Co. Ltd in association with Krushnaji Constro.  
Pune.



**Copy to: -**

1. The Executive Engineer P.W (North) Division, Dhule – for kind information please.
2. The Dy. Engineer, P.W. Sub Division, Shirpur for kind information please.